

REDUCTION OF CARBON MONOXIDE EMISSIONS WITH REGENERATIVE THERMAL OXIDIZERS

Scott Firmin
Passaic Valley Sewerage Commission
Newark, New Jersey

Sheldon Lipke
Passaic Valley Sewerage Commission
Newark, New Jersey

Allen Baturay
Carlson Associates

AUDIENCE QUESTION

How long were the initial valves in operation prior to the identification of corrosive problems and ultimate replacement?

AUTHORS' REPLY

The original valves were cast iron and after four years of operation they became pitted. This resulted in a mixing of inflow gases with the treated outflow gases.